

USQT.S36469 - Extinguishing System Attachments

Extinguishing System Attachments

BERNO FIRE S.L.

S36469

No. 23, Fuente de la Apertura Street
Chapineria (Madrid), 28694 Spain

SPRINKLER SYSTEM ALARM INITIATING DEVICES

Supervisory switches, Models PIS2, OSS.

Wet Pipe, Paddle Type

Model	Size In.	Pipe Schedule	Max System Pressure psig
WAS	2.00	10 through 40	365
	2.5	10 through 40	365
	3.0	10 through 40	365
	4.0	10 through 40	365
	5.0	10 through 40	365
	6.0	10 through 40	365
	8.0	10 through 40	365

Pressure switches, Models PSA10, PSA40 and PSA120.

Last Updated on 2021-05-14

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2021 UL LLC"